

refused admittance to the premises nor shall he be obstructed by any person in making his examination.

220. Power to test water fittings.—The commissioner or other officer may test any water fitting used in connection with water supplied by the corporation.

221. Water pipes, etc., not to be placed where water will be polluted.—(1) No water pipe shall be laid in a drain or on the surface of an open channel or house gully or within six meters of a cesspool or in any position where the pipe is likely to be injured or the water therein polluted; and except with the approval of the corporation no cistern shall be constructed within six meters of a privy or cesspool.

(2) No privy or cesspool shall be constructed or made within six meters of any water pipe or cistern or in any position where the pipe or cistern is likely to be injured or the water therein polluted.

222. Power to cut off water supply.—(1) The commissioner may cut off the supply of water from any premises,—

(a) if the premises are unoccupied;

(b) if the owner or occupier neglects to comply with any lawful order or requisition regarding water supply issued by the commissioner within the period specified therein;

(c) if any charges or any other sum due for water or for the cost of making a connection or the hire of a meter or the cost of carrying out any work or test connected with the water supply which is chargeable to any person by or under this Act is not paid within fifteen days after a bill for such charges or sums has been presented or served;

(d) if after receipt of a notice from the commissioner requiring him to refrain from so doing, the owner or occupier continues to use the water or to permit it to be used